

CERTIFICATE OF CONSTANCY OF PERFORMANCE

Notified Body Nr. 0370

No. **0370-CPR-3639**

In compliance with Regulation (EU) Nr. 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

FIRE DETECTION AND FIRE ALARM SYSTEM.

- SMOKE DETECTORS. POINT DETECTORS USING SCATTERED LIGHT, TRANSMITTED LIGHT OR IONIZATION
- SHORT-CIRCUIT ISOLATORS

MODEL: **ONEDETECTOR1_AP**

Placed on the market under the name of:

TELEDATA, S.R.L.

VIA GIULIETTI, 8
20132 MILANO (ITALY)

And produced in the manufacturing plant:

VIA BRESCIA 24/G
20063 CERNUSCO SUL NAVIGLIO, MILANO (ITALY)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN 54-7:2000, EN 54-7:2000/A1:2002, EN 54-7:2000/A2:2006; EN 54-17:2005, EN 54-17:2005/AC:2007

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 27th September 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. It is confirmed on 1st April 2022.

The monitoring assessment will be done before 31st August 2022

Bellaterra, 1st April 2022

 LGAI Technological Center, S.A.

Xavier Ruiz Peña
Managing Director, Product Conformity B.U.



This document is not valid without its technical annex; whose number coincides with that of the certificate.

You can check the validity of this certificate on our website: www.appluslaboratories.com/certified_products

The manufacturer, after the completion of the conformity assessment procedures and the declaration of performance, may affix the CE Marking under his responsibility



0370-CPR-3639

Annexes according to EN 54-7:2000, EN 54-7:2000/A1: 2002, EN 54-7:2000/A2:2006

FIRE DETECTION AND FIRE ALARM SYSTEM. PART 7: SMOKE DETECTORS. POINT DETECTORS USING SCATTERED LIGHT, TRANSMITTED LIGHT OR IONIZATION

| ESSENTIAL CHARACTERISTICS | CLAUSES IN THIS EUROPEAN STANDARD | MANDATED LEVEL(S) OR CLASS(ES) |
|---|-----------------------------------|--------------------------------|
| Compliance | 4.1 | PASS |
| Individual alarm indication | 4.2 | PASS |
| Connection of ancillary devices | 4.3 | PASS |
| Monitoring of detachable detectors | 4.4 | PASS |
| Manufacturer's adjustments | 4.5 | PASS |
| On-site adjustment of response behaviour | 4.6 | NA |
| Protection against the ingress of foreign bodies | 4.7 | PASS |
| Response to slowly developing fires | 4.8 | NA |
| Marking | 4.9 | PASS |
| Data | 4.10 | PASS |
| Additional requirements for software controlled detectors | 4.11 | PASS |
| Repeatability | 5.2 | PASS |
| Directional dependence | 5.3 | PASS |
| Reproducibility | 5.4 | PASS |
| Variation in supply parameters | 5.5 | NA |
| Air movement | 5.6 | PASS |
| Dazzling | 5.7 | PASS |
| Dry heat (operational) | 5.8 | PASS |
| Cold (operational) | 5.9 | PASS |
| Damp heat, steady state (operational) | 5.10 | PASS |
| Damp heat, steady state (endurance) | 5.11 | PASS |
| Sulfur dioxide (SO ₂) corrosion (endurance) | 5.12 | PASS |
| Shock (operational) | 5.13 | PASS |
| Impact (operational) | 5.14 | PASS |
| Vibration, sinusoidal (operational) | 5.15 | PASS |
| Vibration, sinusoidal (endurance) | 5.16 | PASS |
| Electromagnetic compatibility (EMC), immunity tests (operational) | 5.17 | PASS |
| Fire sensitivity | 5.18 | PASS |

PASS; NPD = No Performance Determined, NA = Not Apply

0370-CPR-3639

Annexes according to **EN 54-17:2005, EN 54-17:2005/AC:2007**

FIRE DETECTION AND FIRE ALARM SYSTEM. PART 17: SHORT-CIRCUIT ISOLATORS

| ESSENTIAL CHARACTERISTICS | CLAUSES IN THIS EUROPEAN STANDARD | MANDATED LEVEL(S) OR CLASS(ES) |
|---|-----------------------------------|--------------------------------|
| Compliance | 4.1 | PASS |
| Integral status indication | 4.2 | NA |
| Connection of ancillary devices | 4.3 | NA |
| Monitoring of detachable short-circuit isolators | 4.4 | NA |
| Manufacturer's adjustments | 4.5 | PASS |
| On-site adjustments | 4.6 | NA |
| Marking | 4.7 | PASS |
| Data | 4.8 | PASS |
| Additional requirements for software controlled short-circuit isolators | 4.9 | PASS |
| Reproducibility | 5.2 | PASS |
| Variation in supply voltage | 5.3 | PASS |
| Dry heat (operational) | 5.4 | PASS |
| Cold (operational) | 5.5 | PASS |
| Damp heat, cyclic (operational) | 5.6 | PASS |
| Damp heat, steady state (endurance) | 5.7 | PASS |
| Sulphur dioxide (SO ₂) corrosion (endurance) | 5.8 | PASS |
| Shock (operational) | 5.9 | PASS |
| Impact (operational) | 5.10 | PASS |
| Vibration, sinusoidal (operational) | 5.11 | PASS |
| Vibration, sinusoidal (endurance)) | 5.12 | PASS |
| Electromagnetic Compatibility (EMC), Immunity tests (operational) | 5.13 | PASS |

PASS; NPd = No Performance Determined, NA = Not Apply

| | |
|----------------------------|---------|
| Ancillary equipment | ONEBASE |
|----------------------------|---------|