

CERTIFICATE OF CONSTANCY OF PERFORMANCE

LGAI Technological Center, S.A. (APPLUS)
Notified Body Nr. 0370

No. **0370-CPR-3645**

In compliance with Regulation (EU) Nr. 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

FIRE DETECTION AND FIRE ALARM SYSTEM.

- FIRE ALARM DEVICES. SOUNDERS
- SHORT-CIRCUIT ISOLATORS
- FIRE ALARM DEVICES. VISUAL ALARM DEVICES

MODEL: **SOUND 110_AP**

Placed on the market under the name of:

TELEDATA, S.R.L.

VIA GIULIETTI, 8
20132 MILANO (ITALY)

And produced in the manufacturing plant:

VIA BRESCIA 24/G
20063 CERNUSCO SUL NAVIGLIO, MILANO (ITALY)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

**EN 54-3:2001, EN 54-3:2001/A1:2002, EN 54-3:2001/A2:2006; EN 54-17:2005, EN 54-17:2005/AC:2007;
EN 54-23:2010**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 27th September 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. It is confirmed on 31st March 2023.

The monitoring assessment will be done before 28th February 2024

Bellaterra, 31st March 2023


LGAI Technological Center, S.A.

Xavier Ruiz Peña
Managing Director, Product Conformity B.U.



This document is not valid without its technical annex; whose number coincides with that of the certificate.

You can check the validity of this certificate on our website: www.appluslaboratories.com/certified_products

The manufacturer, after the completion of the conformity assessment procedures and the declaration of performance, may affix the CE Marking under his responsibility



0370-CPR-3645

Annexes according to **EN 54-3:2001, EN 54-3:2001/A1:2002, EN 54-3:2001/A2:2006**

FIRE DETECTION AND FIRE ALARM SYSTEM. PART 3: FIRE ALARM DEVICES. SOUNDERS

ESSENTIAL CHARACTERISTICS	CLAUSES IN THIS EUROPEAN STANDARD	MANDATED LEVEL(S) OR CLASS(ES)
Sound level	4.2.	PASS
Frequency and sound pattern	4.3.	PASS
Durability	4.4.	PASS
Construction	4.5.	PASS TYPE A
Marking and data	4.6.	PASS
Reproducibility	5.2.	PASS
Operational performance	5.3.	PASS
Durability	5.4.	PASS
Dry heat (operational)	5.5.	PASS
Dry heat (endurance)	5.6.	NA
Cold (operational)	5.7.	PASS
Damp heat, cyclic (operational)	5.8.	PASS
Damp heat, steady state (endurance)	5.9.	PASS
Damp heat, cyclic (endurance)	5.10.	NA
Sulfur dioxide (SO ₂) corrosion (endurance)	5.11.	PASS
Shock (operational)	5.12.	PASS
Impact (operational)	5.13.	PASS
Vibration, sinusoidal (operational)	5.14.	PASS
Vibration, sinusoidal (endurance)	5.15.	PASS
Electromagnetic compatibility (EMC), immunity (operational)	5.16.	PASS
Enclosure protection	5.17.	PASS TYPE A
Attention drawing signal and message broadcast sequences	C.3.1.	NA
Synchronisation (option with requirements)	C.3.2.	NA
General testing	C.4.	NA
Broadcast message performance	C.5.1.	NA
Attention drawing signal/silence/message sequence timing	C.5.2.	NA
Message synchronization testing (option with requirements)	C.5.3.	NA

PASS; NPD = No Performance Determined, NA = Not Apply

0370-CPR-3645

Annexes according to **EN 54-17:2005, EN 54-17:2005/AC:2007**

FIRE DETECTION AND FIRE ALARM SYSTEM. PART 17: SHORT-CIRCUIT ISOLATORS

ESSENTIAL CHARACTERISTICS	CLAUSES IN THIS EUROPEAN STANDARD	MANDATED LEVEL(S) OR CLASS(ES)
Compliance	4.1	PASS
Integral status indication	4.2	NA
Connection of ancillary devices	4.3	NA
Monitoring of detachable short-circuit isolators	4.4	NA
Manufacturer's adjustments	4.5	PASS
On-site adjustments	4.6	NA
Marking	4.7	PASS
Data	4.8	PASS
Additional requirements for software controlled short-circuit isolators	4.9	PASS
Reproducibility	5.2	PASS
Variation in supply voltage	5.3	PASS
Dry heat (operational)	5.4	PASS
Cold (operational)	5.5	PASS
Damp heat, cyclic (operational)	5.6	PASS
Damp heat, steady state (endurance)	5.7	PASS
Sulphur dioxide (SO ₂) corrosion (endurance)	5.8	PASS
Shock (operational)	5.9	PASS
Impact (operational)	5.10	PASS
Vibration, sinusoidal (operational)	5.11	PASS
Vibration, sinusoidal (endurance))	5.12	PASS
Electromagnetic Compatibility (EMC), Immunity tests (operational)	5.13	PASS

PASS; NPd = No Performance Determined, NA = Not Apply

0370-CPR-3645

Annexes according to **EN 54-23:2010**

FIRE DETECTION AND FIRE ALARM SYSTEM. PART 23: FIRE ALARM DEVICES. VISUAL ALARM DEVICES

ESSENTIAL CHARACTERISTICS	CLAUSES IN THIS EUROPEAN STANDARD	MANDATED LEVEL(S) OR CLASS(ES)
Duration of operation	4.2.1	PASS
Provision for external conductors	4.2.2	PASS
Flammability of materials	4.2.3	PASS
Enclosure protection	4.2.4	PASS
Access	4.2.5	PASS
Manufacturer's adjustments	4.2.6	PASS
On-site adjustment of behaviour	4.2.7	PASS
Requirements for software controlled devices	4.2.8	PASS
Coverage volume	4.3.1	PASS W-2,4-5
Variation of light output	4.3.2	PASS
Minimum and maximum light intensity	4.3.3	PASS
Light colour	4.3.4	PASS
Light pattern and frequency of flashing	4.3.5	PASS
Marking and data	4.3.6	PASS
Synchronization (option with requirements)	4.3.7	NA
Temperature resistance	4.4.1	PASS
Humidity resistance	4.4.2	PASS
Shock and vibration resistance	4.4.3	PASS
Corrosion resistance – Sulphur dioxide (SO ₂) (endurance)	4.4.4	PASS
Electrical stability – EMC, immunity (operational)	4.4.5	PASS

PASS; NPD = No Performance Determined, NA = Not Apply