

# SOUND100 SOUND101 SOUND110 SOUND330

Addressed Siren EN54-3, EN54-17 Addressed Siren with Flashing Light EN54-3, EN54-17 Addressed Siren with Flashing Light EN54-3 EN54-17, EN54-23 Addressed Siren with Flashing Light EN54-3 EN54-17, EN54-23, UNI11744 V. 1.1

SOUND100

SOUND101

SOUND110 SOUND330

#### Features

APPLUS approved in compliance with EN54-3 EN54-17 standards (**SOUND100**, **SOUND101**)

- APPLUS approved in compliance with EN54-3 EN54-17 and EN54-23 standards (**SOUND110**)
- APPLUS approved in compliance with EN54-3 EN54-17,EN54-23 and UNI11744 standards (SOUND330)
- ONEPROTOCOLL communication protocol
- Isolator integrated in each device
- Manual addressing via the ONEPROGRAMMER programmer
- Reading of the voltage value at the terminals of the addressed devices
- SOUND100 Certificate n°0370-CPR-3643
- SOUND101 Certificate n°0370-CPR-3644
- SOUND110 Certificate n°0370-CPR-3645
- SOUND330 Certificate n°0370-CPR-1851

#### Description

The new family of addressed sirens of the **SOUND** line extends the range of devices addressed on loops with **ONEPROTOCOLL** protocol.

Simple to install, thanks to the extractable terminal board and the deep base, easy to program using dip switches and jumpers, they comply with EN54-3 and EN54-17 and in the case of **SOUND110** and **SOUND330** also with EN54-23. **SOUND330** model comply with UNI11744.

It can be controlled from the control unit to enable operation of:

- evacuation alarm tone and pre-alarm flashing
- pre-alarm tone and flashing
- muted tone with flashing lights

Each siren can be addressed manually, by ONEPROGRAMMER programmer or by fire detection control unit with ONEPROTOCOLL protocol or with auto addressing by fire detection control unit with ONEPROTOCOLL protocol.

All sirens are equipped with a short-circuit isolator conforming to the EN54-17 standard.

### Guaranteed communication

Teledata

The sirens of the **SOUND** series are equipped with an integrated shortcircuit isolator conforming to the EN54-17 standard.

This means that in the event of a failure on a loop or on a single device, communication with the devices themselves is not interrupted.

Thus greater system reliability is guaranteed.



www.teledata-i.com



# SOUND100 SOUND101 SOUND110 SOUND330

Addressed Siren EN54-3, EN54-17 Addressed Siren with Flashing Light EN54-3, EN54-17 Addressed Siren with Flashing Light EN54-3 EN54-17, EN54-23 Addressed Siren with Flashing Light EN54-3 EN54-17, EN54-23, **UNI11744** 

#### Simplified installation

The installation of the sirens is very simple, the programming of the addresses takes place via the ONEPROGRAMMER programmer. no DIP switches or rotary switches are used.

The connections are facilitated by the presence of an extractable terminal board capable of accommodating cables with a maximum section of 2.5mm, and in addition the base is deep, thus offering more space to facilitate loop wiring.

The degree of protection IP65 is achieved by equipping the base with PG7 cable glands.

#### Construction

The range of addressed sirens in the  $\ensuremath{\textbf{SOUND}}$  line has been designed to be simply installed and programmed.

The plastics are made of glossy red ABS, it is possible to mechanically block the sirens on the base.

## **Technical specifications**

Device	SOUND100	SOUND101	SOUND110	SOUND330	
Туре	Addressed siren	Addressed siren + flashing light	Addressed siren + flashing light EN54-23	Addressed siren + flashing light EN54-23	
Compliance	EN54-3,EN54-17	EN54-3,EN54-17	EN54-3,EN54-17, EN54- 23	EN54-3,EN54-17, EN54-23, UNI11744	
Supply voltage	27V	27V	27V	27V	
Stand by consumption	120uA@27V	120uA@27V	120uA@27V	120uA@27V	
Alarm consumption	7mA@27V-line	25mA@27V-line	28mA@27V-line	28mA@27V-line	
Absorbed power	0,2W	0,6W	1,45W	1,45W	
Coverage			W-2,4-5	W-2,4-5	
Size	D:100mm H:92mm	D:100mm H:92mm	D:100mm H:107mm	D:100mm H:107mm	
Siren voltage ON	24 V dc	24 V dc	24 V dc	24 V dc	
Sound output	107dB	107dB	97dB	97dB	
Certification body		APPLUS			
Protocol		ONEPROTOCOLL			
Operation temperature		-10°C/+55°C			
Humidity		85% RH (without condensation)			
Maximum cable section		2,5mm			
Degree of protection		IP65 (with PG7 cable glands installed in the base)			

#### Approvals and compliance

The entire SOUND sirens range is APPLUS certified according to the EN54 standard parts 3,17 (SOUND100, SOUND101) and parts 3,17,23 (SOUND110, SOUN330).

#### Codes

Code	Description
SOUND100	addressed siren EN54-3, EN54-17
SOUND101	addressed siren with flashing light EN54-3 EN54-17
SOUND110	addressed siren with flashing light EN54-3 EN54-17, EN54- 23
SOUND330	addressed siren with flashing light EN54-3 EN54-17, EN54- 23, UNI11744