

CERTIFICATE OF CONSTANCY OF PERFORMANCE

LGAI Technological Center, S.A. (APPLUS)
Notified Body Nr. 0370

No. **0370-CPR-3635**

In compliance with Regulation (EU) Nr. 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

FIRE DETECTION AND FIRE ALARM SYSTEMS:

- CONTROL AND INDICATING EQUIPMENT
- POWER SUPPLY EQUIPMENT

MODEL: **TELEDATA ONE_AP**

Placed on the market under the name of:

TELEDATA, S.R.L.

VIA GIULIETTI, 8
20132 MILANO (ITALY)

And produced in the manufacturing plant:

VIA BRESCIA 24/G
20063 CERNUSCO SUL NAVIGLIO, MILANO (ITALY)

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

**EN 54-2:1997, EN 54-2:1997/AC:1999, EN 54-2:1997/A1:2006; EN 54-4:1997,
EN 54-4:1997/AC:1999, EN 54-4:1997/A1:2002, EN 54-4:1997/A2:2006**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 27th September 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. It is confirmed and modified on 31st March 2023.

The monitoring assessment will be done before 28th February 2024

Bellaterra, 31st March 2023


LGAI Technological Center, S.A.

Xavier Ruiz Peña
Managing Director, Product Conformity B.U.



This document is not valid without its technical annex; whose number coincides with that of the certificate.

You can check the validity of this certificate on our website: www.appluslaboratories.com/certified_products

The manufacturer, after the completion of the conformity assessment procedures and the declaration of performance, may affix the CE Marking under his responsibility



0370-CPR-3635

Annexes according to **EN 54-2:1997, EN 54-2:1997/AC:1999, EN 54-2:1996/A1:2006**

FIRE DETECTION AND FIRE ALARM SYSTEMS. PART 2: CONTROL AND INDICATING EQUIPMENT

ESSENTIAL CHARACTERISTICS	CLAUSES IN THIS EUROPEAN STANDARD	MANDATED LEVEL(S) OR CLASS(ES)
General requirements	4.	PASS
General requirements for indications	5.	PASS
The quiescent condition	6.	PASS
The fire alarm condition	7.	PASS
Reception and processing of fire signals (see also annex C)	7.1	PASS
Output of the fire alarm condition	7.7	PASS
Output to fire alarm devices (option with requirements)	7.8	PASS
Fault warning condition (see also annex F)	8.	PASS
Fault signals from points (option with requirements)	8.3	PASS
Disabled condition	9.	PASS
Disablement of addressable points (option with requirements)	9.5	PASS
Test condition (option with requirements)	10.	PASS
Standardized input/output interface (option with requirements –see also annex G)	11.	NA
Design requirements	12.	PASS
Additional design requirements for software controlled control and indicating equipment	13.	PASS
Marking	14.	PASS
Cold (operational)	15.4	PASS
Damp heat, steady state (operational)	15.5	PASS
Impact (operational)	15.6	PASS
Vibration, sinusoidal (operational)	15.7	PASS
Electromagnetic Compatibility (EMC)	15.8	PASS
Supply voltage variation (operational)	15.13	PASS
Damp heat, steady state (endurance)	15.14	PASS
Vibration, sinusoidal (endurance)	15.15	PASS

PASS; NPD = No Performance Determined, NA = Not Apply

0370-CPR-3635

Annexes according to **EN 54-4:1997, EN 54-4:1997/AC:1999, EN 54-4:1997/A1:2002, EN 54-4:1997/A2:2006**

FIRE DETECTION AND FIRE ALARM SYSTEMS. PART 4: POWER SUPPLY EQUIPMENT

ESSENTIAL CHARACTERISTICS	CLAUSES IN THIS EUROPEAN STANDARD	MANDATED LEVEL(S) OR CLASS(ES)
General requirements	4.	PASS
Functions	5.	PASS
Materials, design and manufacture	6.	PASS
Documentation	7.	PASS
Marking	8.	PASS
Cold (operational)	9.5	PASS
Damp Heat, steady state (operational)	9.6	PASS
Impact (operational)	9.7	PASS
Vibration, sinusoidal (operational)	9.8	PASS
Electrostatic discharges (operational)	9.9	PASS
Damp heat, steady state (endurance)	9.14	PASS
Vibration, sinusoidal (endurance)	9.15	PASS

PASS; NPD = No Performance Determined, NA = Not Apply