



Constancy of Performance Certificate

LGAI Technological Center S.A. (APPLUS), Notified Body No. 0370, issues this certificate to:

APPLICANT

Placed on the market under the name of

Teledata, S.R.L.

Via Giulietti, 8
20132 Milano (Italy)

Produced in the manufacturing plant

Via Brescia 24/G
20063 Cernusco Sul Naviglio, Milano (Italy)

PRODUCT

Fire detection and fire alarm system

- ☐ Heat detectors. Point detectors
- ☐ Smoke detectors. Point detectors using scattered light, transmitted light or ionization
- ☐ Short-circuit isolators

Model: ONEDETECTOR_AP

APPLICABLE REGULATION

Construction Product Regulation (CPR)

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards:

EN 54-5:2017+A1:2018; EN 54-7:2018; EN 54-17:2005, EN 54-17:2005/AC:2007

Under **system 1** for the performance set out in this certificate are applied and the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

The manufacturer, after the completion of the technical documentation, the conformity assessment procedures and the EU Declaration of conformity, may affix the CE Marking under his responsibility
Page 1 of 4

No. 0370-CPR-3638

Date issued: 07/03/2025

First issue date: 27/09/2019

Follow-up date: before 31/03/2026

The validity of this certificate remains valid as long as the harmonised standard, the construction product, the EVCP methods and the manufacturing conditions at the plant are not significantly modified, unless suspended or withdrawn by the notified product certification body.

This document is not valid without its technical annex; whose number coincides with that of the certificate.

Xavier Ruiz Peña
Managing Director
Conformity Assessment

Applus+
certification

LGAI Technological Center S.A. (APPLUS)
Notified Body No. 0370
Campus UAB. Ronda de la Font del Carme s/n
08193 Bellaterra, Barcelona (Spain)



Check the status
of this certificate

Certificate

Technical Annex

Annex according to EN 54-5:2017+A1:2018

Fire detection and fire alarm system. Part 5: Heat detectors. Point detectors

Essential characteristics	Clauses in this European Standard	Mandated level(s) or class(es)
Heat Response Categories	4.1.1	A1/B Pass
Position of heat sensitive element	4.2.1	Pass
Individual alarm indication	4.2.2	Pass
Connection of ancillary devices	4.2.3	Pass
Monitoring of detachable point heat detectors	4.2.4	Pass
Manufacturing adjustments	4.2.5	Pass
On site adjustment of response behaviour	4.2.6	Na
Software controlled detector	4.2.7	Pass
Directional dependence	4.3.1	Pass
Static response temperature	4.3.2	Pass
Response times from typical application temperature	4.3.3	Pass
Response times from 25 °C	4.3.4	Na
Response times from high ambient temperature	4.3.5	Pass
Reproducibility	4.3.6	Pass
Additional test for suffix S point heat detectors	4.4.1	Na
Additional test for suffix R point heat detectors	4.4.2	Na
Variation in supply parameters	4.5.1	Na
Cold (operational)	4.6.1.1	Pass
Dry heat (endurance)	4.6.1.2	Na
Damp heat, cyclic (operational)	4.6.2.1	Pass
Damp heat, steady state (endurance)	4.6.2.2	Pass
Sulfur dioxide (SO ₂) corrosion (endurance)	4.6.3	Pass
Shock (operational)	4.6.4.1	Pass
Impact (operational)	4.6.4.2	Pass
Vibration, sinusoidal (operational)	4.6.4.3	Pass
Vibration, sinusoidal (endurance)	4.6.4.4	Pass
EMC, immunity (operational)	4.6.5	Pass

Pass; Npd = No performance determined, Na = Not apply

Annex according to EN 54-7:2018

Fire detection and fire alarm system. Part 7: Smoke detectors. Point detectors using scattered light, transmitted light or ionization

Essential characteristics	Clauses in this European Standard	Mandated level(s) or class(es)
Individual alarm indication	4.2.1	Pass
Connection of ancillary devices	4.2.2	Pass
Monitoring of detachable detectors	4.2.3	Pass
Manufacturer's adjustments	4.2.4	Pass
On site adjustment of response behaviour	4.2.5	Na
Protection against the ingress of foreign bodies	4.2.6	Pass
Response to slowly developing fires	4.2.7	Na
Software controlled detector	4.2.8	Pass
Repeatability	4.3.1	Pass
Directional dependence	4.3.2	Pass
Reproducibility	4.3.3	Pass
Air movement	4.4.1	Pass
Dazzling	4.4.2	Pass
Variation in supply parameters	4.5	Na
Fire sensitivity	4.6	Pass
Cold (operational)	4.7.1.1	Pass
Dry heat (operational)	4.7.1.2	Pass
Damp heat, steady state (operational)	4.7.2.1	Pass
Damp heat, steady state (endurance)	4.7.2.2	Pass
Sulfur dioxide (SO ₂) corrosion (endurance)	4.7.3	Pass
Shock (operational)	4.7.4.1	Pass
Impact (operational)	4.7.4.2	Pass
Vibration, sinusoidal (operational)	4.7.4.3	Pass
Vibration, sinusoidal (endurance)	4.7.4.4	Pass
Electromagnetic compatibility (EMC), immunity (operational)	4.7.5	Pass

Pass; Npd = No performance determined, Na = Not apply

Annex according to EN 54-17:2005, EN 54-17:2005/AC:2007

Fire detection and fire alarm system. Part 17: Short-circuit isolators

Essential characteristics	Clauses in this European Standard	Mandated level(s) or class(es)
Compliance	4.1	Pass
Integral status indication	4.2	Na
Connection of ancillary devices	4.3	Na
Monitoring of detachable short-circuit isolators	4.4	Na
Manufacturer's adjustments	4.5	Pass
On-site adjustments	4.6	Na
Marking	4.7	Pass
Data	4.8	Pass
Additional requirements for software controlled short-circuit isolators	4.9	Pass
Reproducibility	5.2	Pass
Variation in supply voltage	5.3	Pass
Dry heat (operational)	5.4	Pass
Cold (operational)	5.5	Pass
Damp heat, cyclic (operational)	5.6	Pass
Damp heat, steady state (endurance)	5.7	Pass
Sulphur dioxide (SO ₂) corrosion (endurance)	5.8	Pass
Shock (operational)	5.9	Pass
Impact (operational)	5.10	Pass
Vibration, sinusoidal (operational)	5.11	Pass
Vibration, sinusoidal (endurance))	5.12	Pass
Electromagnetic Compatibility (EMC), Immunity tests (operational)	5.13	Pass

Pass; Npd = No performance determined, Na = Not apply

Ancillary equipment	ONEBASE
---------------------	---------