

# CERTIFICATE

## of constancy of performance

### 1922 - CPR - 1124

In compliance with Regulation (EU) 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction products

**Fire detection and fire alarm systems. Input/output devices. Short-circuit isolators. Addressable 3 input module with Short-circuit isolator, model: ONEMODULE300; Addressable 3 input/1 supervision output module with Short-circuit Isolator; model: ONEMODULE301; Addressable 1 input/ 1 supervision output/ 1 Form C Output module with Short-circuit Isolator, model: ONEMODULE111; Addressable 1 input/ 2 Form C Output module with short circuit insulator, model: ONEMODULE120; Addressable 3 input/1 Form C output module with Short-circuit Isolator, model ONEMODULE310; Addressable 1 Input/ 1 Form C Output Minimodule with short circuit isolator, model: ONEMODULE110; Addressable 1 Supervised Input Minimodule with short circuit isolator- model: ONEMODULE100; Addressable 1 Supervised Output Minimodule with short circuit isolator- model: ONEMODULE001; ONEMODULEV230 1 Input/ 1 Form C contact clean High power output addressable Minimodule**

(with the performance listed, see Annexes I and II to 1922-CPR-1124 that are an inseparable part of this certificate) placed on the market under the name or trade mark of

**TELEDATA S.R.L**

**Via Giulietti 8, Milano 20132, Italy**

and produced in the manufacturing plant of


**TELEDATA S.R.L**

**Via Brescia 24/G, 20063 Cernusco Sul Naviglio, Milano, Italy**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

**EN 54-18:2005, EN 54-18:2005/AC:2007, EN 54-17:2005, EN 54-17:2005/AC:2007** under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 01.03.2019 and will remain valid until 04.04.2027 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. The certificate is supported through annual surveillance audit and is reissued after each surveillance audit. The validity of the certificate may be confirmed in the CE register at the web address [www.dedal-bg.net](http://www.dedal-bg.net).



Attestation & Certification

Manager:

*Anna Vasileva*

Issued:  
Burgas, 22 August 2024

Ref. No. 04-00

dipl. eng. Anna Vasileva



**ANNEX I TO CERTIFICATE OF CONSTANCY OF PERFORMANCE**  
**1922-CPR-1124/22.08.2024 (page 1 of 1)**

Performance list, acc. to EN 54-18:2005, EN 54-18:2005/AC:2007

Essential Characteristics	Performance	Clause
<b>Response delay (response time)</b>		
- Performance and variation of supply parameters	N/A	5.2
<b>Performance under fire conditions</b>		
- Functional test	Pass	5.1.4
<b>Operational reliability</b>		
- Functional test	Pass	5.1.4
<b>Durability of operational reliability, temperature resistance</b>		
- Dry heat (operational)	Pass	5.3
- Cold (operational)	Pass	5.4
<b>Durability of operational reliability, vibration resistance</b>		
- Shock (operational)	Pass	5.8
- Impact (operational)	Pass	5.9
- Vibration, sinusoidal (operational)	Pass	5.10
- Vibration, sinusoidal (endurance)	Pass	5.11
<b>Durability of operational reliability, humidity resistance</b>		
- Damp heat, cyclic (operational)	Pass	5.5
- Damp heat, steady state (endurance)	Pass	5.6
<b>Durability of operational reliability, corrosion resistance</b>		
- Sulphur dioxide (SO <sub>2</sub> ) corrosion (endurance)	Pass	5.7
<b>Durability of operational reliability, electrical stability</b>		
- Performance and variation of supply parameters	N/A	5.2
- Electromagnetic compatibility (EMC), immunity tests	Pass	5.12

This certificate was first issued on 01.03.2019 and will remain valid until 04.04.2027 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. The certificate is supported through annual surveillance audit and is reissued after each surveillance audit. The validity of the certificate may be confirmed in the CE register at the web address [www.dedal-bg.net](http://www.dedal-bg.net).



Manager:

dipl. eng. Anna Vasileva

Issued:  
Burgas, 22 August 2024

Ref. No. 04-00



## ANNEX II TO CERTIFICATE OF CONSTANCY OF PERFORMANCE 1922-CPR-1124/22.08.2024 (page 1 of 1)

Performance list, acc. to EN 54-17:2005, EN 54-17:2005/AC:2007

Essential Characteristics	Performance	Clause
<b>Performance under fire conditions</b>		
- Reproducibility	Pass	5.2
<b>Operational reliability</b>		
- Requirements	Pass	4
<b>Durability of operational reliability, temperature resistance</b>		
- Dry heat (operational)	Pass	5.4
- Cold (operational)	Pass	5.5
<b>Durability of operational reliability, vibration resistance</b>		
- Shock (operational)	Pass	5.9
- Impact (operational)	Pass	5.10
- Vibration, sinusoidal (operational)	Pass	5.11
- Vibration, sinusoidal (endurance)	Pass	5.12
<b>Durability of operational reliability, humidity resistance</b>		
- Damp heat, cyclic (operational)	Pass	5.6
- Damp heat, steady state (endurance)	Pass	5.7
<b>Durability of operational reliability, corrosion resistance</b>		
- Sulphur dioxide (SO <sub>2</sub> ) corrosion (endurance)	Pass	5.8
<b>Durability of operational reliability, electrical stability</b>		
- Variation of supply parameters	Pass	5.3
- Electromagnetic compatibility (EMC), immunity tests (operational)	Pass	5.13

This certificate was first issued on 01.03.2019 and will remain valid until 04.04.2027 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. The certificate is supported through annual surveillance audit and is reissued after each surveillance audit. The validity of the certificate may be confirmed in the CE register at the web address [www.dedal-bg.net](http://www.dedal-bg.net).



Manager:

*Anna Vasileva*



dipl. eng. Anna Vasileva

Issued:  
Burgas, 22 August 2024

Ref. No. 04-00