



Constancy of Performance Certificate

LGAI Technological Center S.A. (APPLUS), Notified Body No. 0370, issues this certificate to:

APPLICANT

Placed on the market under the name of

Teledata, S.R.L.

Via Giulietti, 8
20132 Milano (Italy)

Manufactured at the production plant

25/32308762

PRODUCT

Fire detection and fire alarm systems

□ Fire alarms devices. Sounders

Model: ONEBASES

APPLICABLE REGULATION

Construction Product Regulation (CPR)

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard:

EN 54-3:2001, EN 54-3:2001/A1:2002, EN 54-3:2001/A2:2006

Under **system 1** for the performance set out in this certificate are applied and the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

No. 0370-CPR-4127

Date issued: 14/11/2025

First issue date: 07/08/2020

Follow-up date: before 30/09/2026

The validity of this certificate remains in effect as long as the harmonised standard, the construction product, the AVCP methods, and the manufacturing conditions at the plant are not significantly modified, unless the certificate is suspended or withdrawn by the notified product certification body.

This document is not valid without its technical annex, whose number coincides with that of the certificate.

Xavier Ruiz Peña
Managing Director
Conformity Assessment

Applus⁺
certification

LGAI Technological Center S.A. (APPLUS)
Notified Body No. 0370
Campus UAB. Ronda de la Font del Carme s/n
08193 Bellaterra, Barcelona (Spain)



Technical Annex

Annex according to EN 54-3:2001, EN 54-3:2001/A1:2002, EN 54-3:2001/A2:2006

Fire detection and fire alarm systems. Part 3: fire alarms devices. Sounders.

Essential characteristics	Clauses in this European standard	Mandated level(s) or class(es)
Sound level	4.2.	Pass
Frequency and sound pattern	4.3.	Pass
Durability	4.4.	Pass
Construction	4.5.	Pass TYPE A
Marking and data	4.6.	Pass
Reproducibility	5.2.	Pass
Operational performance	5.3.	Pass
Durability	5.4.	Pass
Dry heat (operational)	5.5.	Pass
Dry heat (endurance)	5.6.	NA
Cold (operational)	5.7.	Pass
Damp heat, cyclic (operational)	5.8.	Pass
Damp heat, steady state (endurance)	5.9.	Pass
Damp heat, cyclic (endurance)	5.10.	NA
Sulfur dioxide (SO ₂) corrosion (endurance)	5.11.	Pass
Shock (operational)	5.12.	Pass
Impact (operational)	5.13.	Pass
Vibration, sinusoidal (operational)	5.14.	Pass
Vibration, sinusoidal (endurance)	5.15.	Pass
Electromagnetic compatibility (EMC), immunity (operational)	5.16.	Pass
Enclosure protection	5.17.	Pass TYPE A
Attention drawing signal and message broadcast sequences	C.3.1.	NA
Synchronisation (option with requirements)	C.3.2.	NA
General testing	C.4.	NA
Broadcast message performance	C.5.1.	NA
Attention drawing signal/silence/message sequence timing	C.5.2.	NA
Message synchronization testing (option with requirements)	C.5.3.	NA

PASS; NPD = No Performance Determined, NA = Not Apply

Warble tone: 800-1000 Hz, 1 Hz; Continuous tone: 970 Hz

Slow whoop (NL): 500-1200 Hz for 3,5s ON 0,5s OFF; German DIN tone: 1200- 500 Hz, 1 Hz