

Constancy of Performance Certificate

LGAI Technological Center S.A. (APPLUS), Notified Body No. 0370, issues this certificate to:

APPLICANT

Placed on the market under the name of

Teledata, S.r.l.

Via Giulietti, 8
20132 Milano (Italy)

Produced at the manufacturing plant

Via Brescia 24/G
20063 Cernusco Sul Naviglio, Milano (Italy)

PRODUCT

Fire detection and fire alarm system

- Control and indicating equipment
- Power supply equipment.

Models: ONE MINI_AP; ONE MINI LIGHT_AP; ONE MINI SUPERLIGHT_AP

APPLICABLE REGULATION

Construction Product Regulation (CPR)

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards:

EN 54-2:1997, EN 54-2:1997/AC:1999, EN 54-2:1997/A1:2006; EN 54-4:1997, EN 54-4:1997/AC:1999, EN 54-4:1997/A1:2002, EN 54-4:1997/A2:2006

Under **system 1** for the performance set out in this certificate are applied and the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

No. 0370-CPR-3636

Date issued: 13/03/2026

First issue date: 27/09/2019

Expiry date: 31/03/2029

The validity of this certificate remains valid as long as the harmonised standard, the construction product, the EVCP methods and the manufacturing conditions at the plant are not significantly modified, unless suspended or withdrawn by the notified product certification body.

This document is not valid without its technical annex; whose number coincides with that of the certificate.



Xavier Ruiz Peña
Managing Director
Conformity Assessment

Applus⁺ certification

LGAI Technological Center S.A. (APPLUS)
Notified Body No. 0370
Campus UAB. Ronda de la Font del Carme s/n
08193 Bellaterra, Barcelona (Spain)



Check the status
of this certificate

Certificate

Technical Annex

Annex according to EN 54-2:1997, EN 54-2:1997/AC:1999, EN 54-2:1996/A1:2006

Fire detection and fire alarm systems. Part 2: Control and indicating equipment

| Essential characteristics | Clauses in this European Standard | Mandated level(s) or class(es) |
|-----------------------------------------------------------------------------------------|-----------------------------------|--------------------------------|
| General requirements | 4 | Pass |
| General requirements for indications | 5 | Pass |
| The quiescent condition | 6 | Pass |
| The fire alarm condition | 7 | Pass |
| Reception and processing of fire signals (see also annex C) | 7.1 | Pass |
| Output of the fire alarm condition | 7.7 | Pass |
| Fault warning condition (see also annex F) | 8 | Pass |
| Fault signals from points (option with requirements) | 8.3 | Pass |
| Total loss of the power supply (option with requirements) | 8.4 | Pass |
| Disabled condition | 9 | Pass |
| Disablement of addressable points (option with requirements) | 9.5 | Pass |
| Test condition (option with requirements) | 10 | Pass |
| Standardized input/output interface (option with requirements –see also annex G) | 11 | Na |
| Design requirements | 12 | Pass |
| Additional design requirements for software controlled control and indicating equipment | 13 | Pass |
| Marking | 14 | Pass |
| Cold (operational) | 15.4 | Pass |
| Damp heat, steady state (operational) | 15.5 | Pass |
| Impact (operational) | 15.6 | Pass |
| Vibration, sinusoidal (operational) | 15.7 | Pass |
| Electromagnetic Compatibility (EMC) | 15.8 | Pass |
| Supply voltage variation (operational) | 15.13 | Pass |
| Damp heat, steady state (endurance) | 15.14 | Pass |
| Vibration, sinusoidal (endurance) | 15.15 | Pass |

Pass; Npd = No performance determined, Na = Not apply

**Annex according to EN 54-4:1997, EN 54-4:1997/AC:1999,
 EN 54-4:1997/A1:2002, EN 54-4:1997/A2:2006**

Fire detection and fire alarm systems. Part 4: Power Pupply equipment

| Essential characteristics | Clauses in this European Standard | Mandated level(s) or class(es) |
|----------------------------------------|-----------------------------------|--------------------------------|
| General requirements | 4 | Pass |
| Functions | 5 | Pass |
| Materials, design and manufacture | 6 | Pass |
| Documentation | 7 | Pass |
| Marking | 8 | Pass |
| Cold (operational) | 9.5 | Pass |
| Damp Heat, steady state (operational) | 9.6 | Pass |
| Impact (operational) | 9.7 | Pass |
| Vibration, sinusoidal (operational) | 9.8 | Pass |
| Electrostatic discharges (operational) | 9.9 | Pass |
| Damp heat, steady state (endurance) | 9.14 | Pass |
| Vibration, sinusoidal (endurance) | 9.15 | Pass |

Pass; Npd = No performance determined, Na = Not apply