



Constancy of Performance Certificate

LGAI Technological Center S.A. (APPLUS+), Notified Body No. 0370, issues this certificate to:

APPLICANT

Placed on the market under the name of

Teledata, S.r.l.

Via Giulietti, 8
20132 Milano (Italy)

Produced at the manufacturing plant

Via Brescia 24/G
20063 Cernusco Sul Naviglio, Milano (Italy)

PRODUCT

Fire detection and fire alarm system

□ Heat detectors. Point detectors

Model: ONEDETECTOR2 X_AP

APPLICABLE REGULATION

Construction Product Regulation (CPR)

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard:

EN 54-5:2017+A1:2018

Under **system 1** for the performance set out in this certificate are applied and the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

No. 0370-CPR-8118

Date issued: 04/05/2026

Expiry date: 31/03/2029

The validity of this certificate remains valid as long as the harmonised standard, the construction product, the AVCP methods and the manufacturing conditions at the plant are not significantly modified, unless suspended or withdrawn by the notified product certification body.

This document is not valid without its technical annex; whose number coincides with that of the certificate.

Xavier Ruiz Peña
Managing Director
Conformity Assessment



LGAI Technological Center S.A. (APPLUS+)
Notified Body No. 0370
Campus UAB. Ronda de la Font del Carme s/n
08193 Bellaterra, Barcelona (Spain)



Check the status
of this certificate

Certificate

Technical Annex

Annex according to EN 54-5:2017+A1:2018

Fire detection and fire alarm system. Part 5: Heat detectors. Point detectors

Essential characteristics	Clauses in this European Standard	Mandated level(s) or class(es)
Heat Response Categories	4.1.1	A1 & B
Position of heat sensitive element	4.2.1	Pass
Individual alarm indication	4.2.2	Pass
Connection of ancillary devices	4.2.3	Pass
Monitoring of detachable detectors	4.2.4	Pass
Manufacturer's adjustments	4.2.5	Pass
On-site adjustment of response behavior	4.2.6	Pass
Software controlled detector (when provided)	4.2.7	Pass
Directional dependence	4.3.1	Pass
Static response temperature	4.3.2	Pass
Response times from typical application temperature	4.3.3	Pass
Response times from 25 °C	4.3.4	Na
Response times from high ambient temperature	4.3.5	Pass
Reproducibility	4.3.6	Pass
Additional test for heat suffix S detectors	4.4.1	Na
Additional test for heat suffix R detectors	4.4.2	Na
Variation in supply parameters	4.5.1	Pass
Cold (operational)	4.6.1.1	Pass
Dry heat (endurance)	4.6.1.2	Na
Damp heat, cyclic (operational)	4.6.2.1	Na
Damp heat, steady state (endurance)	4.6.2.2	Pass
Sulfur dioxide (SO ₂) corrosión (endurance)	4.6.3	Pass
Shock (operational)	4.6.4.1	Pass
Impact (operational)	4.6.4.2	Pass
Vibration, sinusoidal (operational)	4.6.4.3	Pass
Vibration, sinusoidal (endurance)	4.6.4.4	Pass
EMC, immunity (operational)	4.6.5	Pass

Pass; Npd = No performance determined, Na = Not apply

Ancillary equipment	ONEBASE
---------------------	---------